

# Operation and Maintenance of your Privy



## Your system includes:

- An above grade privy structure (designs may vary)
- A holding tank (minimum 500 gallon capacity)

***Tank cleaning must be performed by a registered septage hauler. Contact the health department for a complete list of registered contractors.***

## Operation and Maintenance Instructions

1. Keep solid wastes, such as cigarette butts, tampons, sanitary napkins, or other trash out of the holding tank.
2. Do not dispose of waste water into the privy holding tank.
3. Have the tank pumped and cleaned by a registered septage hauler as needed to prevent tank overfill or any unsanitary condition.
4. Maintain the privy structure to ensure proper fly control. This includes keeping vent screens and self closing door in good condition.